



**PLAN VIEW**  
1 : 12  
MOUNTING HOLE POSITIONS ONLY

**NOTES :**

- 1) INLET FLOW IS EITHER GRAVITY FED OR PUMPED TO HEADER TANK (VIA WASTE WATER INLET) AND FILTRATE FLOW TO COLLECTION POINT IS BY GRAVITY.
  - 2) A SELF DRAINING SKIP (OR SUITABLE MECHANICAL EQUIVALENT) IS REQUIRED FOR "SPADE-ABLE" SOLIDS COLLECTION AND A MIST COVER (OR HOOD) IS REQUIRED AT FRONT OR UNIT.
  - 3) ALL ANCILLARY WORKS (PIPING, SERVICES, SUMP, SHED, SUPPORT SLAB, SOLIDS SKIP, ETC) TO BE SUPPLIED AND INSTALLED BY THE CLIENT.
  - 4) SERVICES REQUIRED TO OPERATE THE FILTER ARE PROVIDED BY THE PUMP CONTROL UNIT (REFER TO INSTALLATION PROFORMA) OUTLET CONNECTIONS
  - 5) SECURING THE FILTER UNIT TO A RIGID NON-VIBRATIONAL STRUCTURE (OR FOUNDATION) IS RECOMMENDED.
  - 6) WATER FROM DEWATERING SOLIDS COLLECTION SKIP MAY BE DIRECTED EITHER TO FILTRATE OR TO OTHER SUITABLE LOCATION (SUBJECT TO SITE SURVEY).
  - 7) FINAL SPECIFICATIONS ARE BASED ON INDIVIDUAL SITE REQUIREMENTS.
  - 8) UPSTREAM PRETREATMENTS AND INFLUENT BALANCING MAY BE REQUIRED (SUBJECT TO SITE SURVEY).
- FOR FURTHER INFORMATION PLEASE CONTACT YOUR LOCAL BALEEN REPRESENTATIVE.

DRAWN	SER	<b>BALEEN FILTERS PTY LTD</b>	DESCRIPTION	PROJECT
DATE	21/08/02		<b>COTTAGE FILTER UNIT INSTALLATION PROFORMA</b>	<b>C1</b>
EDITED	SER	168 Melbourne Street, North Adelaide SA 5006 AUSTRALIA Tel: +61 8 8239 2422 Fax: +61 8 8239 0722 email: info@baleenfilters.com	DRG No.	REV
DATE	25/04/03		<b>10W10C</b>	<b>FINAL</b>